

IEC 61850 Certificate - IEC 61850 Certificate #2039

Hyosung NeoProPAC-GBC [Hyosung]

07/08/2021 04:23 PM - Herbert Falk

| | | | |
|-------------------------------------|--|---------------------------------------|--|
| Status: | Approved | Test Document: | |
| Priority: | Normal | Certificate Name: | 74100348-NMEA/INC 11-1103 |
| 61850 Edition: | Edition 1 | Certificate Hash: | 58D01B3C6D58657C8D1E1DDE7B939 5522DE1F945370C2EF229F773AB182 B5C56 |
| 61850 Tested Aspects: | Server | Vendor Artifact File Name: | |
| Company: | Hyosung | Vendor Artifact Hash: | |
| Address: | 183-2 Hogye-dong, Dongan-gu ANYANG GYEONGGI-DO 431-080 KOREA | Umbrella Organization: | |
| Product: | Hyosung NeoProPAC-GBC | Optional Reservation Test: | No |
| HW Version: | 1.2 | Serial Number: | |
| SW Version: | 1.0 | Publisher Legacy Variants: | |
| Key Words: | | Publisher Preferred Rates: | |
| Test Procedure Version: | 2.2b | Publisher Preferred Variants: | |
| IEC 61850 Blocks Certified: | Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5) | Subscriber Legacy Variants: | |
| Certificate/Result Reviewer: | rebecca.davenport,kathy.ellis | Subscriber Preferred Variants: | |
| Approval Date: | 07/15/2015 | Subscriber Preferred Rates: | |
| Standards Tested: | 61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1 | | |
| Current Test Lab Name: | DNV Netherlands (A) | | |

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:23 PM - Herbert Falk

- File 11-1103_Hyosung_NeoProPac-GBC_Certificate.pdf added

Files

| | | | |
|---|--------|------------|--------------|
| 11-1103_Hyosung_NeoProPac-GBC_Certificate.pdf | 313 KB | 07/08/2021 | Herbert Falk |
|---|--------|------------|--------------|