

IEC 61850 Certificate - IEC 61850 Certificate #2040

Hyosung NeoProPAC-TBU [Hyosung]

07/08/2021 04:23 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	74100348-NMEA/INC 11-1105
61850 Edition:	Edition 1	Certificate Hash:	FA4EC1929B7FFE602FA9EED871EA79 2B2D75025A01A79EF5F75FB299F0F86 992
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	Hyosung	Vendor Artifact Hash:	
Address:	183-2 Hogye-dong, Dongan-gu ANYANG GYEONGGI-DO 431-080 KOREA	Umbrella Organization:	
Product:	Hyosung NeoProPAC-TBU	Optional Reservation Test:	No
HW Version:	0.1	Serial Number:	
SW Version:	1.0	Publisher Legacy Variants:	
Key Words:		Publisher Preferred Rates:	
Test Procedure Version:	2.2b	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	rebecca.davenport,kathy.ellis	Subscriber Preferred Variants:	
Approval Date:	07/15/2015	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:23 PM - Herbert Falk

- File 11-1105_Hyosung_NeoProPac-TBU_Certificate.pdf added

Files

11-1105_Hyosung_NeoProPac-TBU_Certificate.pdf	309 KB	07/08/2021	Herbert Falk
---	--------	------------	--------------