

IEC 61850 Certificate - IEC 61850 Certificate #2042

SEL-751 Feeder Protection Rela [Schweitzer Engineering Laboratories, Inc.]

07/08/2021 04:23 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	74100372-MOC/INC 11-1380
61850 Edition:	Edition 1	Certificate Hash:	4C459960C3E1CB0E8D9955DAB6399B 56923A5839CD013D730E3E0E581D4B AC32
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	Schweitzer Engineering Laboratories, Inc.	Vendor Artifact Hash:	
Address:	2350 NE Hopkins Court Pullman,WA 99163-5603 USA	Umbrella Organization:	
Product:	SEL-751 Feeder Protection Rela	Optional Reservation Test:	No
HW Version:		Serial Number:	
SW Version:	R100	Publisher Legacy Variants:	
Key Words:	Protection, Relay	Publisher Preferred Rates:	
Test Procedure Version:	2.2b	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	rebecca.davenport,kathy.ellis	Subscriber Preferred Variants:	
Approval Date:	07/15/2015	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		

Description
This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:23 PM - Herbert Falk

- File 11-1380_SEL_751_Certificate.pdf added

Files

11-1380_SEL_751_Certificate.pdf	785 KB	07/08/2021	Herbert Falk
---------------------------------	--------	------------	--------------