

IEC 61850 Certificate - IEC 61850 Certificate #2045

MCA4 Protection and Control [Woodward Kempen GmbH]

07/08/2021 04:23 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	30107056-MOC/INC 11-1499
61850 Edition:	Edition 1	Certificate Hash:	71BD6BBFFBFB744680A36865824F06 5A5589C33A57EA3B49B2FE2DB9A07B 4896
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	Woodward Kempen GmbH	Vendor Artifact Hash:	
Address:	Krefelder Weg 47 D-47906 Kempen Germany	Umbrella Organization:	
Product:	MCA4 Protection and Control	Optional Reservation Test:	No
HW Version:		Serial Number:	
SW Version:	2.0.h	Publisher Legacy Variants:	
Key Words:	Protection, Relay	Publisher Preferred Rates:	
Test Procedure Version:	2.2b	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	rebecca.davenport,kathy.ellis	Subscriber Preferred Variants:	
Approval Date:	07/17/2015	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		

Description
This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:23 PM - Herbert Falk

- File 11-1499_Woodward_MCA4_Certificate.pdf added

Files

11-1499_Woodward_MCA4_Certificate.pdf	745 KB	07/08/2021	Herbert Falk
---------------------------------------	--------	------------	--------------