

IEC 61850 Certificate - IEC 61850 Certificate #2049

SLP-K120 [SANION Co., Ltd.]

07/08/2021 04:23 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	74100358-MOC/INC 11-1740
61850 Edition:	Edition 1	Certificate Hash:	2D07C11A7A75E4864CE1F3340A1761 54B3B654C2B9EC31554FEB653269F4 1E2C
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	SANION Co., Ltd.	Vendor Artifact Hash:	
Address:	#208 Acetechno Tower, 55-7 Mullae-Dong 3Ga, Yeongdeungpo-Gu, Seoul, 150-992, South Korea	Umbrella Organization:	
Product:	SLP-K120	Optional Reservation Test:	No
HW Version:	1.2	Serial Number:	
SW Version:	1.0	Publisher Legacy Variants:	
Key Words:	Protection	Publisher Preferred Rates:	
Test Procedure Version:	2.2b	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	rebecca.davenport,bruce.muschlitz	Subscriber Preferred Variants:	
Approval Date:	07/17/2015	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-4, 61850-8-1		
Current Test Lab Name:	ABB Switzerland Ltd. (B)		
Description			
This certificate and its information was migrated from a previous database			

History

#1 - 07/08/2021 04:23 PM - Herbert Falk

- File 11-1740_Sanion_SLP-K120_Certificate.pdf added

Files

11-1740_Sanion_SLP-K120_Certificate.pdf	423 KB	07/08/2021	Herbert Falk
---	--------	------------	--------------