

IEC 61850 Certificate - IEC 61850 Certificate #2052

SEL-311L Line Current Differen [Schweitzer Engineering Laboratories, Inc.]

07/08/2021 04:23 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	74100372-MOC/INC 11-1941
61850 Edition:	Edition 1	Certificate Hash:	B1E4C8FF61929FE08E4DD95D4DB33 A52267F4B8EF6A8B41F8A797143BAC 1A735
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	Schweitzer Engineering Laboratories, Inc.	Vendor Artifact Hash:	
Address:	2350 NE Hopkins Court Pullman, WA 99163-5603 USA	Umbrella Organization:	
Product:	SEL-311L Line Current Differen	Optional Reservation Test:	No
HW Version:		Serial Number:	
SW Version:	R413	Publisher Legacy Variants:	
Key Words:	Differential, Protection	Publisher Preferred Rates:	
Test Procedure Version:	2.2b	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	rebecca.davenport,kathy.ellis	Subscriber Preferred Variants:	
Approval Date:	07/17/2015	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		

Description
This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:23 PM - Herbert Falk

- File 11-1941_SEL_311L_Certificate.pdf added

Files

11-1941_SEL_311L_Certificate.pdf	784 KB	07/08/2021	Herbert Falk
----------------------------------	--------	------------	--------------