IEC 61850 Certificate - IEC 61850 Certificate #2055

SEL-351A Protection System [Schweitzer Engineering Laboratories, Inc.]

07/08/2021 04:23 PM - Herbert Falk

Status:	Approved		
Priority:	Normal		
61850 Edition:	Edition 1	**Certificate Name:**	74100372-MOC/INC 11-2028
61850 Tested Aspects:	Server	**Certificate Hash:**	76AC40B82E9AB9D10E96FB9C7EDBED8B02F8C3BF3E33CA187268B337B65E533C
Company:	Schweitzer Engineering Laboratories, Inc.	**Vendor Artifact File Name:**	
Address:	2350 NE Hopkins Court Pullman, WA 99163-5603 USA	**Vendor Artifact Hash:**	
Product:	SEL-351A Protection System	**Umbrella Organization:**	
HW Version:		**Optional Reservation Test:**	No
SW Version:	R599	**Serial Number:**	
Key Words:	Protection	**Publisher Legacy Variants:**	
Test Procedure Version:	2.2b	**Publisher Preferred Rates:**	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Unbuffered Reporting (B5)	**Publisher Preferred Variants:**	
Certificate/Result Reviewer:	rebecca.davenport,kathy.ellis	**Subscriber Legacy Variants:**	
Approval Date:	07/17/2015	**Subscriber Preferred Variants:**	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1	**Subscriber Preferred Rates:**	
Current Test Lab Name:	DNV Netherlands (A)	**Product Variants:**	
Test Document:			

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:23 PM - Herbert Falk

- File 11-2028_SEL_351A_Certificate.pdf added

Files

11-2028_SEL_351A_Certificate.pdf	340 KB	07/08/2021	Herbert Falk