

IEC 61850 Certificate - IEC 61850 Certificate #2056

SEL-311C Transmission Prot. [Schweitzer Engineering Laboratories, Inc.]

07/08/2021 04:23 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	74100372-MOC/INC 11-2030
61850 Edition:	Edition 1	Certificate Hash:	979EC981FA55A43A8296EACAAA3030 D054F4C685A3ED8F892D6977DB5FE0 44B9
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	Schweitzer Engineering Laboratories, Inc.	Vendor Artifact Hash:	
Address:	2350 NE Hopkins Court Pullman, WA 99163-5603 USA	Umbrella Organization:	
Product:	SEL-311C Transmission Prot.	Optional Reservation Test:	No
HW Version:		Serial Number:	
SW Version:	R599	Publisher Legacy Variants:	
Key Words:	Protection	Publisher Preferred Rates:	
Test Procedure Version:	2.2b	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	rebecca.davenport,kathy.ellis	Subscriber Preferred Variants:	
Approval Date:	07/17/2015	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		
Description			
This certificate and its information was migrated from a previous database			

History

#1 - 07/08/2021 04:23 PM - Herbert Falk

- File 11-2030_SEL_311C_Certificate.pdf added

Files

11-2030_SEL_311C_Certificate.pdf	339 KB	07/08/2021	Herbert Falk
----------------------------------	--------	------------	--------------