

IEC 61850 Certificate - IEC 61850 Certificate #2058

SEL-487B Bus Differential [Schweitzer Engineering Laboratories, Inc.]

07/08/2021 04:23 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	74100372-MOC/INC 11-2038
61850 Edition:	Edition 1	Certificate Hash:	A29FF0E6DB4D917225CD0B90599D7F F7B440799A82D95908DA8A95297B646 D8C
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	Schweitzer Engineering Laboratories, Inc.	Vendor Artifact Hash:	
Address:	2350 NE Hopkins Court Pullman, WA 99163-5603 USA	Umbrella Organization:	
Product:	SEL-487B Bus Differential	Optional Reservation Test:	No
HW Version:		Serial Number:	
SW Version:	R300	Publisher Legacy Variants:	
Key Words:	Differential, Relay	Publisher Preferred Rates:	
Test Procedure Version:	2.2b	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	rebecca.davenport,kathy.ellis	Subscriber Preferred Variants:	
Approval Date:	07/17/2015	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:23 PM - Herbert Falk

- File 11-2038_SEL_487B_Certificate.pdf added

Files

11-2038_SEL_487B_Certificate.pdf

339 KB

07/08/2021

Herbert Falk