

IEC 61850 Certificate - IEC 61850 Certificate #2060

RTU560 [ABB AG]

07/08/2021 04:23 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	74101960-MOC/INC 12-02107
61850 Edition:	Edition 1	Certificate Hash:	9E421FD4C0E0C328CBD7CE5447A59 834FCB62B0D41CCFA7E658E9B9FB5 BE8506
61850 Tested Aspects:	Client	Vendor Artifact File Name:	
Company:	ABB AG	Vendor Artifact Hash:	
Address:	Kallstadter Str 1 68309, Mannheim Germany	Umbrella Organization:	
Product:	RTU560	Optional Reservation Test:	No
HW Version:		Serial Number:	
SW Version:	10.6	Publisher Legacy Variants:	
Key Words:		Publisher Preferred Rates:	
Test Procedure Version:	1.1	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), SBO Control (12b), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	rebecca.davenport,bruce.muschlitz	Subscriber Preferred Variants:	
Approval Date:	07/19/2015	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:23 PM - Herbert Falk

- File 12-02107_ABB_RTU560_Client_Certificate.pdf added

Files

12-02107_ABB_RTU560_Client_Certificate.pdf	279 KB	07/08/2021	Herbert Falk
--	--------	------------	--------------