

# IEC 61850 Certificate - IEC 61850 Certificate #2062

## PROZA NET [Koncar - Power Plant and Electric]

07/08/2021 04:24 PM - Herbert Falk

<b>Status:</b>	Approved	<b>Test Document:</b>	
<b>Priority:</b>	Normal	<b>Certificate Name:</b>	ZE 15 08 89991 002
<b>61850 Edition:</b>	Edition 2	<b>Certificate Hash:</b>	62AC506B035C84268FD223FFADF5A8 9309CD70A120994F0469594CC62D564 BD9
<b>61850 Tested Aspects:</b>	Client	<b>Vendor Artifact File Name:</b>	
<b>Company:</b>	Koncar - Power Plant and Electric	<b>Vendor Artifact Hash:</b>	
<b>Address:</b>	Fallerovo setaliste 22 HR-10000 ZAGREB Croatia	<b>Umbrella Organization:</b>	
<b>Product:</b>	PROZA NET	<b>Optional Reservation Test:</b>	Yes
<b>HW Version:</b>	Lenovo W520 w/Win 7 Pro SP1	<b>Serial Number:</b>	
<b>SW Version:</b>	3.2.10.2	<b>Publisher Legacy Variants:</b>	
<b>Key Words:</b>		<b>Publisher Preferred Rates:</b>	
<b>Test Procedure Version:</b>	1.0	<b>Publisher Preferred Variants:</b>	
<b>IEC 61850 Blocks Certified:</b>	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), SBO Control (12b), Service Tracking (B15), Setting Group (B4), Setting Group Definition (B4+), Substitution (B3), Time Synchronization (B13), Unbuffered Reporting (B5)	<b>Subscriber Legacy Variants:</b>	
<b>Certificate/Result Reviewer:</b>	kathy.ellis	<b>Subscriber Preferred Variants:</b>	
<b>Approval Date:</b>	08/05/2015	<b>Subscriber Preferred Rates:</b>	
<b>Standards Tested:</b>	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
<b>Current Test Lab Name:</b>	TUV SUD Germany (A)		
<b>Description</b>			
This certificate and its information was migrated from a previous database			

### History

#1 - 07/08/2021 04:24 PM - Herbert Falk

- File ZE 15 07 89991 002 IEC 61850 Ed2 Client Certificate PROZA NE added

#2 - 07/11/2021 10:02 AM - Herbert Falk

- Address updated

- Optional Reservation Test changed from No to Yes

### Files

