

IEC 61850 Certificate - IEC 61850 Certificate #2063

zenon Supervisor/Energy Ed. [Ing. Punzenberger COPA-DATA GmbH]

07/08/2021 04:24 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	ZE 15 07 90699 002
61850 Edition:	Edition 2	Certificate Hash:	0C28E68782DC1FDCA7CB4318FA05A ADA785D566C64C5E26D8174B55D642 6565F
61850 Tested Aspects:	Client	Vendor Artifact File Name:	
Company:	Ing. Punzenberger COPA-DATA GmbH	Vendor Artifact Hash:	
Address:	Karolingerstr. 7B 5020, Salzburg Austria	Umbrella Organization:	
Product:	zenon Supervisor/Energy Ed.	Optional Reservation Test:	Yes
HW Version:	HP Z440 Workstation/Win 7 Pro	Serial Number:	
SW Version:	7.50	Publisher Legacy Variants:	
Key Words:		Publisher Preferred Rates:	
Test Procedure Version:	1.0	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), SBO Control (12b), Service Tracking (B15), Setting Group (B4), Setting Group Definition (B4+), Substitution (B3), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	kathy.ellis	Subscriber Preferred Variants:	
Approval Date:	08/13/2015	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	TUV SUD Germany (A)		
Description			
This certificate and its information was migrated from a previous database			

History

#1 - 07/08/2021 04:24 PM - Herbert Falk

- File ZE 15 07 90699 002 COPA-DATA zenon Supervisor IEC 61850 Ed 2 added

#2 - 07/11/2021 10:03 AM - Herbert Falk

- Address updated

- Optional Reservation Test changed from No to Yes

Files

ZE 15 07 90699 002 COPA-DATA zenon Supervisor IEC 61850 Ed 2.pdf 43 MB

07/08/2021

Herbert Falk