

# IEC 61850 Certificate - IEC 61850 Certificate #2064

## Emax2 w/Ekip -air circuit brea [ABB SACE Division]

07/08/2021 04:24 PM - Herbert Falk

<b>Status:</b>	Approved	<b>Test Document:</b>	
<b>Priority:</b>	Normal	<b>Certificate Name:</b>	1KHL050076
<b>61850 Edition:</b>	Edition 1	<b>Certificate Hash:</b>	A0E45BB2ECED9187B25E8ACBC1B00 59BFE10E9E63F3EFDF54667FD49BF8 61B78
<b>61850 Tested Aspects:</b>	Server	<b>Vendor Artifact File Name:</b>	
<b>Company:</b>	ABB SACE Division	<b>Vendor Artifact Hash:</b>	
<b>Address:</b>	A division of ABB S.p.A. L.V. Breakers L.V. Products Division Italy 24123 Bergamo	<b>Umbrella Organization:</b>	
<b>Product:</b>	Emax2 w/Ekip -air circuit brea	<b>Optional Reservation Test:</b>	No
<b>HW Version:</b>	429011219010W010	<b>Serial Number:</b>	
<b>SW Version:</b>	2.10	<b>Publisher Legacy Variants:</b>	
<b>Key Words:</b>	Breaker	<b>Publisher Preferred Rates:</b>	
<b>Test Procedure Version:</b>	2.3	<b>Publisher Preferred Variants:</b>	
<b>IEC 61850 Blocks Certified:</b>	Basic Exchange (B1), Data Sets (B2), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), Unbuffered Reporting (B5)	<b>Subscriber Legacy Variants:</b>	
<b>Certificate/Result Reviewer:</b>	kathy.ellis,bruce.muschlitz	<b>Subscriber Preferred Variants:</b>	
<b>Approval Date:</b>	08/13/2015	<b>Subscriber Preferred Rates:</b>	
<b>Standards Tested:</b>	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
<b>Current Test Lab Name:</b>	ABB Switzerland Ltd. (B)		
<b>Description</b>			
This certificate and its information was migrated from a previous database			

### History

#1 - 07/08/2021 04:24 PM - Herbert Falk

- File 1KHL050076\_Emax2\_IEC61850Ed1ConformanceCertificate.pdf added

### Files

1KHL050076_Emax2_IEC61850Ed1ConformanceCertificate.pdf	1.3 MB	07/08/2021	Herbert Falk
--	--------	------------	--------------