

IEC 61850 Certificate - IEC 61850 Certificate #2065

PAC-XF100 Feeder Protection [PNC Technologies Co., Ltd.]

07/08/2021 04:24 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	2015TS01996
61850 Edition:	Edition 1	Certificate Hash:	48CA5BA96CA679721AF3095C5DACE F202A9E3F18DAF0FC3855E0DC596E7 18601
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	PNC Technologies Co., Ltd.	Vendor Artifact Hash:	
Address:	62, Jeonpa-ro 104beon-gil, Dongan-gu, Anyang-si Gyeonggi-do, 14042 Republic of Korea	Umbrella Organization:	
Product:	PAC-XF100 Feeder Protection	Optional Reservation Test:	No
HW Version:		Serial Number:	
SW Version:	1.00	Publisher Legacy Variants:	
Key Words:	Protection, Relay	Publisher Preferred Rates:	
Test Procedure Version:	2.3	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	kathy.ellis	Subscriber Preferred Variants:	
Approval Date:	08/19/2015	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	Korea Electrotechnology Research Institute (A)		
Description			
This certificate and its information was migrated from a previous database			

History

#1 - 07/08/2021 04:24 PM - Herbert Falk

- File 2015TS01996_PNCTech_PAC-XF100_Server1.0_KERI.pdf added

Files

2015TS01996_PNCTech_PAC-XF100_Server1.0_KERI.pdf	3 MB	07/08/2021	Herbert Falk
--------------------------------------------------	------	------------	--------------