

IEC 61850 Certificate - IEC 61850 Certificate #2071

TRF300 Protection and Control [YPP Corporation]

07/08/2021 04:24 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	2014TS02168
61850 Edition:	Edition 1	Certificate Hash:	713D0898FC8CBF10FE3BB92F1971E1 772A42E57F6D2770967D6B6CE7B209 00F0
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	YPP Corporation	Vendor Artifact Hash:	
Address:	YPP Building, 327-30, Gasan-Dong Kumchun-Gu, Seoul, 153-802 Republic of Korea	Umbrella Organization:	
Product:	TRF300 Protection and Control	Optional Reservation Test:	No
HW Version:	1.00	Serial Number:	
SW Version:	1.00	Publisher Legacy Variants:	
Key Words:	Protection, Relay	Publisher Preferred Rates:	
Test Procedure Version:	2.3	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Setting Group (B4), Setting Group Definition (B4+), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	kathy.ellis	Subscriber Preferred Variants:	
Approval Date:	08/23/2015	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	Korea Electrotechnology Research Institute (A)		
Description			
This certificate and its information was migrated from a previous database			

History

#1 - 07/08/2021 04:24 PM - Herbert Falk

- File 2014TS02168_YPP_TRF300_TRM300_TRT300_KERI.PDF added

Files

2014TS02168_YPP_TRF300_TRM300_TRT300_KERI.PDF	2.73 MB	07/08/2021	Herbert Falk
---	---------	------------	--------------