

# IEC 61850 Certificate - IEC 61850 Certificate #2073

## GIPAM-DL CPT Feeder Protection [LSIS Co., Ltd.]

07/08/2021 04:24 PM - Herbert Falk

<b>Status:</b>	Approved	<b>Test Document:</b>	
<b>Priority:</b>	Normal	<b>Certificate Name:</b>	2014TS02484
<b>61850 Edition:</b>	Edition 1	<b>Certificate Hash:</b>	C367EE4E37B4885E9CD492285F5667 C56C4FBF2EC356E57100CD38D84190 ED7D
<b>61850 Tested Aspects:</b>	Server	<b>Vendor Artifact File Name:</b>	
<b>Company:</b>	LSIS Co., Ltd.	<b>Vendor Artifact Hash:</b>	
<b>Address:</b>	LS Tower, 127 LS-Ro, Dongan-Gu, Anyang-si, Gyeonggi-do Republic of Korea	<b>Umbrella Organization:</b>	
<b>Product:</b>	GIPAM-DL CPT Feeder Protection	<b>Optional Reservation Test:</b>	No
<b>HW Version:</b>		<b>Serial Number:</b>	
<b>SW Version:</b>	02.00 08.17	<b>Publisher Legacy Variants:</b>	
<b>Key Words:</b>	Protection, Relay	<b>Publisher Preferred Rates:</b>	
<b>Test Procedure Version:</b>	2.3	<b>Publisher Preferred Variants:</b>	
<b>IEC 61850 Blocks Certified:</b>	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	<b>Subscriber Legacy Variants:</b>	
<b>Certificate/Result Reviewer:</b>	kathy.ellis	<b>Subscriber Preferred Variants:</b>	
<b>Approval Date:</b>	08/23/2015	<b>Subscriber Preferred Rates:</b>	
<b>Standards Tested:</b>	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
<b>Current Test Lab Name:</b>	Korea Electrotechnology Research Institute (A)		

### Description

This certificate and its information was migrated from a previous database

### History

#1 - 07/08/2021 04:24 PM - Herbert Falk

- File 2014TS02484\_L SIS\_GIPAM-DL\_CPT\_KERI.pdf added

### Files

2014TS02484_L SIS_GIPAM-DL_CPT_KERI.pdf	2.38 MB	07/08/2021	Herbert Falk
---	---------	------------	--------------