

IEC 61850 Certificate - IEC 61850 Certificate #2074

GIPAM-DL PT Voltage Protection [LSIS Co., Ltd.]

07/08/2021 04:24 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	2014TS02485
61850 Edition:	Edition 1	Certificate Hash:	C36F1106648A06B2C410C6144BBDE9 5FF1591E8E769F8748BD5F39C0A760 AB86
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	LSIS Co., Ltd.	Vendor Artifact Hash:	
Address:	LS Tower, 127 LS-Ro, Dongan-Gu, Anyang-si, Gyeonggi-do Republic of Korea	Umbrella Organization:	
Product:	GIPAM-DL PT Voltage Protection	Optional Reservation Test:	No
HW Version:	02.00 08.17	Serial Number:	
SW Version:		Publisher Legacy Variants:	
Key Words:	Protection, Relay	Publisher Preferred Rates:	
Test Procedure Version:	2.3	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	kathy.ellis	Subscriber Preferred Variants:	
Approval Date:	08/23/2015	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	Korea Electrotechnology Research Institute (A)		

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:24 PM - Herbert Falk

- File 2014TS02485_L SIS_GIPAM-DL_PT_KERI.pdf added

Files

2014TS02485_L SIS_GIPAM-DL_PT_KERI.pdf	2.41 MB	07/08/2021	Herbert Falk
----------------------------------------	---------	------------	--------------