

# IEC 61850 Certificate - IEC 61850 Certificate #2081

## CMU6-100 [Hanbit EDS Co., Ltd.]

07/08/2021 04:25 PM - Herbert Falk

<b>Status:</b>	Approved	<b>Test Document:</b>	
<b>Priority:</b>	Normal	<b>Certificate Name:</b>	2015TS00985
<b>61850 Edition:</b>	Edition 1	<b>Certificate Hash:</b>	5E6494F10E2B1E6FBFF0497F3821BC 8A8BD6D86FD3ADFA77F8CFF53170B 93536
<b>61850 Tested Aspects:</b>	Server	<b>Vendor Artifact File Name:</b>	
<b>Company:</b>	Hanbit EDS Co., Ltd.	<b>Vendor Artifact Hash:</b>	
<b>Address:</b>	4-10 Techno 10-ro, Yuseong-gu, Daejeon, 305510 Republic of Korea	<b>Umbrella Organization:</b>	
<b>Product:</b>	CMU6-100	<b>Optional Reservation Test:</b>	No
<b>HW Version:</b>	HP Z620 w/Windows 7	<b>Serial Number:</b>	
<b>SW Version:</b>	1.1	<b>Publisher Legacy Variants:</b>	
<b>Key Words:</b>		<b>Publisher Preferred Rates:</b>	
<b>Test Procedure Version:</b>	2.3	<b>Publisher Preferred Variants:</b>	
<b>IEC 61850 Blocks Certified:</b>	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Enhanced SBO Control (12d), Time Synchronization (B13)	<b>Subscriber Legacy Variants:</b>	
<b>Certificate/Result Reviewer:</b>	kathy.ellis,bruce.muschlitz	<b>Subscriber Preferred Variants:</b>	
<b>Approval Date:</b>	08/23/2015	<b>Subscriber Preferred Rates:</b>	
<b>Standards Tested:</b>	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
<b>Current Test Lab Name:</b>	Korea Electrotechnology Research Institute (A)		
<b>Description</b>			
This certificate and its information was migrated from a previous database			

### History

#1 - 07/08/2021 04:25 PM - Herbert Falk

- File 2015TS00985\_HanbitEDS\_CMU6-100\_Server1.0\_KERI\_Certificate.pdf added

### Files

2015TS00985\_HanbitEDS\_CMU6-100\_Server1.0\_KERI\_Certificate.pdf 1.83 MB

07/08/2021

Herbert Falk