

IEC 61850 Certificate - IEC 61850 Certificate #2083

P40 AGILE (P14DZ) [ALSTOM Grid UK LTD]

07/08/2021 04:25 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	50745.6040.801
61850 Edition:	Edition 1	Certificate Hash:	A0A862A2633AA368C244242A30E6377 AE838F2E0D9A75C8561195949C3D5D 619
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	ALSTOM Grid UK LTD	Vendor Artifact Hash:	
Address:	St. Leonards Avenue Stafford, ST17 4LX United Kingdom	Umbrella Organization:	
Product:	P40 AGILE (P14DZ)	Optional Reservation Test:	No
HW Version:	A	Serial Number:	
SW Version:	50H	Publisher Legacy Variants:	
Key Words:		Publisher Preferred Rates:	
Test Procedure Version:	2.3	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	kathy.ellis	Subscriber Preferred Variants:	
Approval Date:	08/23/2015	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	Grid Automation Laboratories (B)		

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:25 PM - Herbert Falk

- File 50745.6040.801_ALSTOM_P40Agile_P14DZ_Certificate.pdf added

#2 - 08/04/2021 09:37 AM - Herbert Falk

- Current Test Lab Name changed from UK Grid Solutions Ltd (B) to Grid Automation Laboratories (B)

Files

50745.6040.801_ALSTOM_P40Agile_P14DZ_Certificate.pdf	984 KB	07/08/2021	Herbert Falk
--	--------	------------	--------------