

# IEC 61850 Certificate - IEC 61850 Certificate #2090

## Areva MiCom P341 [Areva T&D UK Ltd.]

07/08/2021 04:25 PM - Herbert Falk

<b>Status:</b>	Approved	<b>Test Document:</b>	
<b>Priority:</b>	Normal	<b>Certificate Name:</b>	50745.6341.801
<b>61850 Edition:</b>	Edition 1	<b>Certificate Hash:</b>	284FF126B328A339D92440C91626696 B44D54263C75C9E233CFF3583ED3FC CE6
<b>61850 Tested Aspects:</b>	Server	<b>Vendor Artifact File Name:</b>	
<b>Company:</b>	Areva T&D UK Ltd.	<b>Vendor Artifact Hash:</b>	
<b>Address:</b>	St. Leonards Avenue Stafford, ST17 4LX United Kingdom	<b>Umbrella Organization:</b>	
<b>Product:</b>	Areva MiCom P341	<b>Optional Reservation Test:</b>	No
<b>HW Version:</b>	J	<b>Serial Number:</b>	
<b>SW Version:</b>	70A	<b>Publisher Legacy Variants:</b>	
<b>Key Words:</b>	Protection, Relay	<b>Publisher Preferred Rates:</b>	
<b>Test Procedure Version:</b>	2.2	<b>Publisher Preferred Variants:</b>	
<b>IEC 61850 Blocks Certified:</b>	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	<b>Subscriber Legacy Variants:</b>	
<b>Certificate/Result Reviewer:</b>	kathy.ellis	<b>Subscriber Preferred Variants:</b>	
<b>Approval Date:</b>	08/28/2015		
<b>Standards Tested:</b>	61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
<b>Current Test Lab Name:</b>	Grid Automation Laboratories (B)		

### Description

This certificate and its information was migrated from a previous database

### History

#1 - 07/08/2021 04:25 PM - Herbert Falk

- File 50745.6341.801\_AREVA\_P34170J\_Certificate.pdf added

#2 - 08/04/2021 09:37 AM - Herbert Falk

- Current Test Lab Name changed from UK Grid Solutions Ltd (B) to Grid Automation Laboratories (B)

### Files

50745.6341.801_AREVA_P34170J_Certificate.pdf	225 KB	07/08/2021	Herbert Falk
--	--------	------------	--------------