

IEC 61850 Certificate - IEC 61850 Certificate #2102

SIPROTEC 7SC805 Merging Unit [Siemens A.G., IC SG EA]

07/08/2021 04:25 PM - Herbert Falk

Status:	Approved	
Priority:	Normal	
61850 Edition:	Edition 1	Certificate Name: 74105994-OPE/INC 14-1574
61850 Tested Aspects:	Merging Unit	Certificate Hash: C04AF694DF19DD65FBE743176C21C67962BEDB4F829703E2B864DD2CE0A97A15
Company:	Siemens A.G., IC SG EA	Vendor Artifact File Name:
Address:	Protection and Substation Control Systems Wernerwerkdamm 5 D-13623 Berlin Germany	Vendor Artifact Hash:
Product:	SIPROTEC 7SC805 Merging Unit	Umbrella Organization:
HW Version:	7SC80542AB963FM0	Optional Reservation Test: No
SW Version:	04.50	Serial Number:
Key Words:	Merging Unit	Publisher Legacy Variants: F4000S1I4U4, F4800S1I4U4
Test Procedure Version:	1.1	Publisher Preferred Rates:
IEC 61850 Blocks Certified:	Sampled Value Publish (11a)	Publisher Preferred Variants:
Certificate/Result Reviewer:	kathy.ellis	Subscriber Legacy Variants:
Approval Date:	08/29/2015	Subscriber Preferred Variants:
Standards Tested:	61850-6, 61850-7-2, 61850-9-2, UCAlug 9-2LE	Subscriber Preferred Rates:
Current Test Lab Name:	DNV Netherlands (A)	Product Variants:
Test Document:		Time Activated Control:
Description This certificate and its information was migrated from a previous database		

History

#1 - 07/08/2021 04:25 PM - Herbert Falk

- File 14-1574_Siemens_7SC805_92LE_Certificate.pdf added

#2 - 06/13/2022 03:14 PM - Bruce Muschlitz

- Address updated

- Publisher Legacy Variants F4000S1I4U4, F4800S1I4U4 added

Files

14-1574_Siemens_7SC805_92LE_Certificate.pdf	2.57 MB	07/08/2021	Herbert Falk
---	---------	------------	--------------