IEC 61850 Certificate - IEC 61850 Certificate #2109

Siprotec V4 7SD6 [Siemens A.G., PTD EA]

07/08/2021 04:26 PM - Herbert Falk

Status:	Approved		
Priority:	Normal		
61850 Edition:	Edition 1	**Certificate Name:**	30720460-Consulting 07-1359
61850 Tested Aspects:	Server	**Certificate Hash:**	A5BF0A02DCC08A373A666862B05B0558C687B63BDAD9467759973C2ECF8A951E
Company:	Siemens A.G., PTD EA	**Vendor Artifact File Name:**	
Address:	Protection and Substation Control Systems Wernerwerkdamm 5 D-13623 Berlin Germany	**Vendor Artifact Hash:**	
Product:	Siprotec V4 7SD6	**Umbrella Organization:**	
HW Version:	EN100 V04.00	**Optional Reservation Test:**	No
SW Version:	04.60	**Serial Number:**	
Key Words:	Differential, Protection	**Publisher Legacy Variants:**	
Test Procedure Version:	2.2	**Publisher Preferred Rates:**	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	**Publisher Preferred Variants:**	
Certificate/Result Reviewer:	kathy.ellis	**Subscriber Legacy Variants:**	
Approval Date:	08/30/2015	**Subscriber Preferred Variants:**	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1	**Subscriber Preferred Rates:**	
Current Test Lab Name:	DNV Netherlands (A)	**Product Variants:**	
Test Document:			

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:26 PM - Herbert Falk

- File 07-1359_Siemens_7SD6_Certificate.pdf added

Files

07-1359_Siemens_7SD6_Certificate.pdf	295 KB	07/08/2021	Herbert Falk