

IEC 61850 Certificate - IEC 61850 Certificate #2132

VAMP50 [VAMP Ltd.]

07/08/2021 04:26 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	74100458-MOC/INC 11-2634
61850 Edition:	Edition 1	Certificate Hash:	98025CE450344E91C88B6C38FA7B9E FA91479499FADC69C08261EC1A988B 9B93
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	VAMP Ltd.	Vendor Artifact Hash:	
Address:	P.O. Box 810 FIN-65101 Vaasa, Finland Visiting Address: Yrittajankatu 15	Umbrella Organization:	Schneider Electric
Product:	VAMP50	Optional Reservation Test:	No
HW Version:		Serial Number:	
SW Version:	10.87	Publisher Legacy Variants:	
Key Words:		Publisher Preferred Rates:	
Test Procedure Version:	2.2b	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	kathy.ellis	Subscriber Preferred Variants:	
Approval Date:	08/30/2015	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:26 PM - Herbert Falk

- File 11-2634_PC_VAMP50_Certificate.pdf added

#2 - 07/09/2021 09:17 AM - Herbert Falk

- Umbrella Organization set to Schneider Electric

Files

11-2634_PC_VAMP50_Certificate.pdf	491 KB	07/08/2021	Herbert Falk
-----------------------------------	--------	------------	--------------