IEC 61850 Certificate - IEC 61850 Certificate #2134

VAMP257 [VAMP Ltd.]

07/08/2021 04:26 PM - Herbert Falk

Status:	Approved		
Priority:	Normal		
61850 Edition:	Edition 1	**Certificate Name:**	74100458-MOC/INC 11-2638
61850 Tested Aspects:	Server	**Certificate Hash:**	701BC3835EDFDC9BE7F805B1D24D9133726CCC8AF1A329280F5869B943A28302
Company:	VAMP Ltd.	**Vendor Artifact File Name:**	
Address:	P.O. Box 810 FIN-65101 Vaasa, Finland Visiting Address: Yrittajankatu 15	**Vendor Artifact Hash:**	
Product:	VAMP257	**Umbrella Organization:**	Schneider Electric
HW Version:		**Optional Reservation Test:**	No
SW Version:	10.87	**Serial Number:**	
Key Words:		**Publisher Legacy Variants:**	
Test Procedure Version:	2.2b	**Publisher Preferred Rates:**	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Unbuffered Reporting (B5)	**Publisher Preferred Variants:**	
Certificate/Result Reviewer:	kathy.ellis	**Subscriber Legacy Variants:**	
Approval Date:	08/30/2015	**Subscriber Preferred Variants:**	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1	**Subscriber Preferred Rates:**	
Current Test Lab Name:	DNV Netherlands (A)	**Product Variants:**	
Test Document:			

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:26 PM - Herbert Falk

- File 11-2638_PC_VAMP257_Certificate.pdf added

#2 - 07/09/2021 09:17 AM - Herbert Falk

- Umbrella Organization set to Schneider Electric

Files

11-2638_PC_VAMP257_Certificate.pdf	489 KB	07/08/2021	Herbert Falk