

IEC 61850 Certificate - IEC 61850 Certificate #2140

SYMAP-Y [Stucke Elektronik GmbH]

07/08/2021 04:27 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	74100446-MOC/INC 12-00073
61850 Edition:	Edition 1	Certificate Hash:	D767ADAF6DAC35BB20FC77A8FFAA8 C2B633C007B9089A4DC2918E27F229 A0C05
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	Stucke Elektronik GmbH	Vendor Artifact Hash:	
Address:	Merkurring 26 22143 Hamburg Germany	Umbrella Organization:	
Product:	SYMAP-Y	Optional Reservation Test:	No
HW Version:		Serial Number:	
SW Version:	1.10	Publisher Legacy Variants:	
Key Words:	Protection, Relay	Publisher Preferred Rates:	
Test Procedure Version:	2.2b	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	kathy.ellis	Subscriber Preferred Variants:	
Approval Date:	08/30/2015	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		
Description			
This certificate and its information was migrated from a previous database			

History

#1 - 07/08/2021 04:27 PM - Herbert Falk

- File 12-00073_Stucke_SYMAP-Y_Certificate.pdf added

Files

12-00073_Stucke_SYMAP-Y_Certificate.pdf	343 KB	07/08/2021	Herbert Falk
---	--------	------------	--------------