

# IEC 61850 Certificate - IEC 61850 Certificate #2141

## REB650 [ABB AB]

07/08/2021 04:27 PM - Herbert Falk

<b>Status:</b>	Approved	<b>Test Document:</b>	
<b>Priority:</b>	Normal	<b>Certificate Name:</b>	74101125-MOC/INC 12-00232
<b>61850 Edition:</b>	Edition 1	<b>Certificate Hash:</b>	6E36C94AD1CC9347D229AA9FA1E88 BA7C7164FC5A2C9C4D519C87185539 872EC
<b>61850 Tested Aspects:</b>	Server	<b>Vendor Artifact File Name:</b>	
<b>Company:</b>	ABB AB	<b>Vendor Artifact Hash:</b>	
<b>Address:</b>	SA Products S-721 59 Vasteras Sweden	<b>Umbrella Organization:</b>	
<b>Product:</b>	REB650	<b>Optional Reservation Test:</b>	No
<b>HW Version:</b>	1MRK001535-22	<b>Serial Number:</b>	
<b>SW Version:</b>	1.2.0.B2	<b>Publisher Legacy Variants:</b>	
<b>Key Words:</b>		<b>Publisher Preferred Rates:</b>	
<b>Test Procedure Version:</b>	2.2b	<b>Publisher Preferred Variants:</b>	
<b>IEC 61850 Blocks Certified:</b>	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Setting Group (B4), Substitution (B3), Time Synchronization (B13), Unbuffered Reporting (B5)	<b>Subscriber Legacy Variants:</b>	
<b>Certificate/Result Reviewer:</b>	kathy.ellis	<b>Subscriber Preferred Variants:</b>	
<b>Approval Date:</b>	08/30/2015	<b>Subscriber Preferred Rates:</b>	
<b>Standards Tested:</b>	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4		
<b>Current Test Lab Name:</b>	DNV Netherlands (A)		

### Description

This certificate and its information was migrated from a previous database

### History

#1 - 07/08/2021 04:27 PM - Herbert Falk

- File 12-00232\_ABB\_REB650\_certificate.pdf added

### Files

12-00232_ABB_REB650_certificate.pdf	286 KB	07/08/2021	Herbert Falk
-------------------------------------	--------	------------	--------------