

IEC 61850 Certificate - IEC 61850 Certificate #2143

MBP-H1A [Mitsubishi Electric Corporation]

07/08/2021 04:27 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	74101045-MOC/INC 12-00262
61850 Edition:	Edition 1	Certificate Hash:	7440B3720DE47D2B143EAFE90091AE 3ECC427BBE7721747C41AE7941D8D4 643A
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	Mitsubishi Electric Corporation	Vendor Artifact Hash:	
Address:	Protection & Control Systems Transmission & Distribution Systems Center Kobe, Japan	Umbrella Organization:	
Product:	MBP-H1A	Optional Reservation Test:	No
HW Version:	SCHEME No. 472PTA	Serial Number:	
SW Version:	PGJP21 E/PGJP22 G/PGJP28 B	Publisher Legacy Variants:	
Key Words:	Protection, Relay	Publisher Preferred Rates:	
Test Procedure Version:	2.3	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Setting Group (B4), Setting Group Definition (B4+), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	kathy.ellis	Subscriber Preferred Variants:	
Approval Date:	08/30/2015	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		
Description			
This certificate and its information was migrated from a previous database			

History

#1 - 07/08/2021 04:27 PM - Herbert Falk

- File 12-00262_Mitsubishi_MBP-H1A_Certificate.pdf added

Files

12-00262_Mitsubishi_MBP-H1A_Certificate.pdf	283 KB	07/08/2021	Herbert Falk
---	--------	------------	--------------