

# IEC 61850 Certificate - IEC 61850 Certificate #2151

## XGIPAM [LSIS Co., Ltd.]

07/08/2021 04:27 PM - Herbert Falk

<b>Status:</b>	Approved	<b>Test Document:</b>	
<b>Priority:</b>	Normal	<b>Certificate Name:</b>	2015TS02059
<b>61850 Edition:</b>	Edition 1	<b>Certificate Hash:</b>	CC32839B774F6C734A7B47FD7995CF 63B973A04900A85B15443F4DAAC397 5794
<b>61850 Tested Aspects:</b>	Server	<b>Vendor Artifact File Name:</b>	
<b>Company:</b>	LSIS Co., Ltd.	<b>Vendor Artifact Hash:</b>	
<b>Address:</b>	LS Tower, 127 LS-RO, Dongan-Gu, Anytang-Si, Gyeonggi-Do Republic of Korea	<b>Umbrella Organization:</b>	
<b>Product:</b>	XGIPAM	<b>Optional Reservation Test:</b>	No
<b>HW Version:</b>		<b>Serial Number:</b>	
<b>SW Version:</b>	3.0	<b>Publisher Legacy Variants:</b>	
<b>Key Words:</b>	Protection, Relay	<b>Publisher Preferred Rates:</b>	
<b>Test Procedure Version:</b>	2.3	<b>Publisher Preferred Variants:</b>	
<b>IEC 61850 Blocks Certified:</b>	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	<b>Subscriber Legacy Variants:</b>	
<b>Certificate/Result Reviewer:</b>	kathy.ellis	<b>Subscriber Preferred Variants:</b>	
<b>Approval Date:</b>	09/04/2015	<b>Subscriber Preferred Rates:</b>	
<b>Standards Tested:</b>	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
<b>Current Test Lab Name:</b>	Korea Electrotechnology Research Institute (A)		
<b>Description</b>			
This certificate and its information was migrated from a previous database			

### History

#1 - 07/08/2021 04:27 PM - Herbert Falk

- File 2015TS02059\_L SIS\_XGIPAM\_Server1.0\_KERI.pdf added

### Files

2015TS02059_L SIS_XGIPAM_Server1.0_KERI.pdf	2.96 MB	07/08/2021	Herbert Falk
---	---------	------------	--------------