

# IEC 61850 Certificate - IEC 61850 Certificate #2152

## YHFP500 Fire Preventive IED [YOUHO ELECTRIC IND. CO., LTD.]

07/08/2021 04:27 PM - Herbert Falk

<b>Status:</b>	Approved	<b>Test Document:</b>	
<b>Priority:</b>	Normal	<b>Certificate Name:</b>	2015TS02058
<b>61850 Edition:</b>	Edition 1	<b>Certificate Hash:</b>	BB5C0DDDBA38E53C81614E4186C1BA 048E8AB272CCE9850BAC6C324EB98 B90C07
<b>61850 Tested Aspects:</b>	Server	<b>Vendor Artifact File Name:</b>	
<b>Company:</b>	YOUHO ELECTRIC IND. CO., LTD.	<b>Vendor Artifact Hash:</b>	
<b>Address:</b>	217, Hwahap-Ro, Gwangjeok-Myeon, Yangju-Si, Gyeonggi-Do, Republic of Korea	<b>Umbrella Organization:</b>	
<b>Product:</b>	YHFP500 Fire Preventive IED	<b>Optional Reservation Test:</b>	No
<b>HW Version:</b>		<b>Serial Number:</b>	
<b>SW Version:</b>	1.0	<b>Publisher Legacy Variants:</b>	
<b>Key Words:</b>		<b>Publisher Preferred Rates:</b>	
<b>Test Procedure Version:</b>	2.3	<b>Publisher Preferred Variants:</b>	
<b>IEC 61850 Blocks Certified:</b>	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	<b>Subscriber Legacy Variants:</b>	
<b>Certificate/Result Reviewer:</b>	kathy.ellis	<b>Subscriber Preferred Variants:</b>	
<b>Approval Date:</b>	09/04/2015		
<b>Standards Tested:</b>	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
<b>Current Test Lab Name:</b>	Korea Electrotechnology Research Institute (A)		
<b>Description</b>			
This certificate and its information was migrated from a previous database			

### History

#1 - 07/08/2021 04:27 PM - Herbert Falk

- File 2015TS02058\_YOUHO\_YHFP500\_Server1.0\_KERI.pdf added

### Files

2015TS02058_YOUHO_YHFP500_Server1.0_KERI.pdf	2.94 MB	07/08/2021	Herbert Falk
--	---------	------------	--------------