

# IEC 61850 Certificate - IEC 61850 Certificate #2153

## Siprotec V5 7VK87 [Siemens A.G., IC SG EA]

07/08/2021 04:27 PM - Herbert Falk

<b>Status:</b>	Approved	<b>Test Document:</b>	
<b>Priority:</b>	Normal	<b>Certificate Name:</b>	74101158-MOC/INC 12-00465
<b>61850 Edition:</b>	Edition 1	<b>Certificate Hash:</b>	3E478A938EF2D56374B11446156D138 F412F5B8FDFD25687212C3C07018C1 51B
<b>61850 Tested Aspects:</b>	Server	<b>Vendor Artifact File Name:</b>	
<b>Company:</b>	Siemens A.G., IC SG EA	<b>Vendor Artifact Hash:</b>	
<b>Address:</b>	Protection and Substation Control Systems Wernerwerkdamm 5 D-13623 Berlin Germany	<b>Umbrella Organization:</b>	
<b>Product:</b>	Siprotec V5 7VK87	<b>Optional Reservation Test:</b>	No
<b>HW Version:</b>		<b>Serial Number:</b>	
<b>SW Version:</b>	1.10	<b>Publisher Legacy Variants:</b>	
<b>Key Words:</b>		<b>Publisher Preferred Rates:</b>	
<b>Test Procedure Version:</b>	2.3	<b>Publisher Preferred Variants:</b>	
<b>IEC 61850 Blocks Certified:</b>	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced Buffered Reporting (B6+), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Setting Group (B4), Setting Group Definition (B4+), Substitution (B3), Time Synchronization (B13), Unbuffered Reporting (B5)	<b>Subscriber Legacy Variants:</b>	
<b>Certificate/Result Reviewer:</b>	kathy.ellis	<b>Subscriber Preferred Variants:</b>	
<b>Approval Date:</b>	09/04/2015	<b>Subscriber Preferred Rates:</b>	
<b>Standards Tested:</b>	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
<b>Current Test Lab Name:</b>	DNV Netherlands (A)		

### Description

This certificate and its information was migrated from a previous database

### History

#1 - 07/08/2021 04:27 PM - Herbert Falk

- File 12-00465\_Siemens\_7VK87\_Certificate.pdf added

### Files

12-00465\_Siemens\_7VK87\_Certificate.pdf

286 KB

07/08/2021

Herbert Falk