

IEC 61850 Certificate - IEC 61850 Certificate #2154

Siprotec V5 6MD85 Bay Controll [Siemens A.G., IC SG EA]

07/08/2021 04:27 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	74101158-MOC/INC 12-00467
61850 Edition:	Edition 1	Certificate Hash:	BDE0EBA403861A9DA435D0BD4CFC1 A5BC6EBA187C2B186D13C7F8AAE2E 0526B1
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	Siemens A.G., IC SG EA	Vendor Artifact Hash:	
Address:	Protection and Substation Control Systems Wernerwerkdamm 5 D-13623 Berlin Germany	Umbrella Organization:	
Product:	Siprotec V5 6MD85 Bay Controll	Optional Reservation Test:	No
HW Version:		Serial Number:	
SW Version:	1.10	Publisher Legacy Variants:	
Key Words:		Publisher Preferred Rates:	
Test Procedure Version:	2.3	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced Buffered Reporting (B6+), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Setting Group (B4), Setting Group Definition (B4+), Substitution (B3), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	kathy.ellis	Subscriber Preferred Variants:	
Approval Date:	09/04/2015	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:27 PM - Herbert Falk

- File 12-00467_Siemens_6MD85_Certificate.pdf added

Files

12-00467_Siemens_6MD85_Certificate.pdf

286 KB

07/08/2021

Herbert Falk