

IEC 61850 Certificate - IEC 61850 Certificate #2163

SEL-651R Recloser Control [Schweitzer Engineering Laboratories, Inc.]

07/08/2021 04:27 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	74100372-MOC/INC 12-00747
61850 Edition:	Edition 1	Certificate Hash:	F04F83AADA1FDD2078052BC23613A2 E31F3B24E7E0AA51F3B8845E32F4C1 8F5B
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	Schweitzer Engineering Laboratories, Inc.	Vendor Artifact Hash:	
Address:	2350 NE Hopkins Court Pullman, WA 99163-5603 USA	Umbrella Organization:	
Product:	SEL-651R Recloser Control	Optional Reservation Test:	No
HW Version:		Serial Number:	
SW Version:	R400	Publisher Legacy Variants:	
Key Words:		Publisher Preferred Rates:	
Test Procedure Version:	2.2b	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	kathy.ellis	Subscriber Preferred Variants:	
Approval Date:	09/04/2015	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:27 PM - Herbert Falk

- File 12-00747_SEL_651R_Certificate.pdf added

Files

12-00747_SEL_651R_Certificate.pdf

343 KB

07/08/2021

Herbert Falk