

IEC 61850 Certificate - IEC 61850 Certificate #2167

P725B [RTK Instruments]

07/08/2021 04:28 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	74101429-MOC/INC 12-00988
61850 Edition:	Edition 1	Certificate Hash:	B056FCD5BDAC2103C60C8B513D045 9C3593B5B5EACED8586FF6D8A26A9 B23A8B
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	RTK Instruments	Vendor Artifact Hash:	
Address:	St. James Business Park Knaresborough, UK HG5 8PJ England	Umbrella Organization:	
Product:	P725B	Optional Reservation Test:	No
HW Version:		Serial Number:	
SW Version:	GPC 2.19.12 DCCP 2.12.0	Publisher Legacy Variants:	
Key Words:		Publisher Preferred Rates:	
Test Procedure Version:	2.3	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	kathy.ellis,bruce.muschlitz	Subscriber Preferred Variants:	
Approval Date:	09/04/2015	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		
Description			
This certificate and its information was migrated from a previous database			

History

#1 - 07/08/2021 04:28 PM - Herbert Falk

- File 12-00988_RTK_P725B_Certificate.pdf added

Files

12-00988_RTK_P725B_Certificate.pdf	278 KB	07/08/2021	Herbert Falk
------------------------------------	--------	------------	--------------