

IEC 61850 Certificate - IEC 61850 Certificate #2171

SUF-K110 [SANION Co., Ltd.]

07/08/2021 04:28 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	74101969-MOC/INC 12-01368
61850 Edition:	Edition 1	Certificate Hash:	96974314771AB14EFFAD7AB9B85512 9E8E9B1507C6A887FC92E77787FFA3 3FD5
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	SANION Co., Ltd.	Vendor Artifact Hash:	
Address:	#208, Acetechno Tower, 12 Dangsang-Ro 2-Gil, Yeongdeungpo-Gu, Seoul, Republic of Korea	Umbrella Organization:	
Product:	SUF-K110	Optional Reservation Test:	No
HW Version:	1.0	Serial Number:	
SW Version:	1.0	Publisher Legacy Variants:	
Key Words:		Publisher Preferred Rates:	
Test Procedure Version:	2.2b	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	kathy.ellis	Subscriber Preferred Variants:	
Approval Date:	09/05/2015	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		
Description			
This certificate and its information was migrated from a previous database			

History

#1 - 07/08/2021 04:28 PM - Herbert Falk

- File 12-01368_Sanion_SUF-K110_Certificate.pdf added

Files

12-01368_Sanion_SUF-K110_Certificate.pdf	310 KB	07/08/2021	Herbert Falk
--	--------	------------	--------------