

IEC 61850 Certificate - IEC 61850 Certificate #2179

MiCOM P545 [ALSTOM Grid UK LTD]

07/08/2021 04:28 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	74100457-MOC/INC 12-01469
61850 Edition:	Edition 1	Certificate Hash:	2B2CC84956E3EB20CEE96E82EA43D 310515B026F22A07C972A32CDED6C1 B2006
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	ALSTOM Grid UK LTD	Vendor Artifact Hash:	
Address:	St. Leonards Avenue Stafford ST17 4LX United Kingdom	Umbrella Organization:	
Product:	MiCOM P545	Optional Reservation Test:	No
HW Version:		Serial Number:	
SW Version:	71C	Publisher Legacy Variants:	
Key Words:		Publisher Preferred Rates:	
Test Procedure Version:	2.3	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Subscribe (9b), SBO Control (12b), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	kathy.ellis	Subscriber Preferred Variants:	
Approval Date:	09/05/2015	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:28 PM - Herbert Falk

- File 12-01469_Alstom_Grid_P545_certificate.pdf added

Files

12-01469_Alstom_Grid_P545_certificate.pdf	232 KB	07/08/2021	Herbert Falk
---	--------	------------	--------------