

IEC 61850 Certificate - IEC 61850 Certificate #2180

YSDPI-9800 [YOUSUNG Instrument & Electric Co., Ltd.]

07/08/2021 04:28 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	74101864-MOC/INC 12-01488
61850 Edition:	Edition 1	Certificate Hash:	7314CB1EA45BFD91163DFBA2D8B50 B1A0C177DC1DFA4E84A0FFDD18F66 0E1510
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	YOUSUNG Instrument & Electric Co., Ltd.	Vendor Artifact Hash:	
Address:	#7-13, Songdo-dong, Yeonsu-gu Incheon Republic of Korea	Umbrella Organization:	
Product:	YSDPI-9800	Optional Reservation Test:	No
HW Version:	1.01	Serial Number:	
SW Version:	1.01	Publisher Legacy Variants:	
Key Words:	Relay	Publisher Preferred Rates:	
Test Procedure Version:	2.2b	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	kathy.ellis,bruce.muschlitz	Subscriber Preferred Variants:	
Approval Date:	09/05/2015	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:28 PM - Herbert Falk

- File 12-01488_YousungInstrument_YSDPI-9800_Certificate.pdf added

Files

12-01488_YousungInstrument_YSDPI-9800_Certificate.pdf	298 KB	07/08/2021	Herbert Falk
---	--------	------------	--------------