

IEC 61850 Certificate - IEC 61850 Certificate #2181

YSVR-2110A [YOUSUNG Instrument & Electric Co., Ltd.]

07/08/2021 04:28 PM - Herbert Falk

Status:	Approved	
Priority:	Normal	
61850 Edition:	Edition 1	Certificate Name: 74101864-MOC/INC 12-01490
61850 Tested Aspects:	Server	Certificate Hash: C7ABC979CD5D94BA47750C86B6724 C4764A5DB4C75D6DC5D55DCA4064C 3D1B8C
Company:	YOUSUNG Instrument & Electric Co., Ltd.	Vendor Artifact File Name:
Address:	#7-13, Songdo-dong, Yeonsu-gu Incheon Republic of Korea	Vendor Artifact Hash:
Product:	YSVR-2110A	Umbrella Organization:
HW Version:	1.00	Optional Reservation Test: No
SW Version:	1.03	Serial Number:
Key Words:	Relay	Publisher Legacy Variants:
Test Procedure Version:	2.2b	Publisher Preferred Rates:
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Unbuffered Reporting (B5)	Publisher Preferred Variants:
Certificate/Result Reviewer:	kathy.ellis,bruce.muschlitz	Subscriber Legacy Variants:
Approval Date:	09/05/2015	Subscriber Preferred Variants:
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1	Subscriber Preferred Rates:
Current Test Lab Name:	DNV Netherlands (A)	Product Variants:
Test Document:		Time Activated Control:
Description This certificate and its information was migrated from a previous database		

History

#1 - 07/08/2021 04:28 PM - Herbert Falk

- File 12-01490_YousungInstrument_YSVR-2110A_Certificate.pdf added

Files

12-01490_YousungInstrument_YSVR-2110A_Certificate.pdf	295 KB	07/08/2021	Herbert Falk
---	--------	------------	--------------