

IEC 61850 Certificate - IEC 61850 Certificate #2182

SO-52v11 [Mikronika]

07/08/2021 04:28 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	74101901-MOC/INC 12-01513
61850 Edition:	Edition 1	Certificate Hash:	872183A5C19A12CB5D831012EBC2A6 57E81E2B010228D1BBC1EA3185522F C40E
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	Mikronika	Vendor Artifact Hash:	
Address:	60-001 Poznan Wykopy 2/4 Poland	Umbrella Organization:	
Product:	SO-52v11	Optional Reservation Test:	No
HW Version:		Serial Number:	
SW Version:	1.4	Publisher Legacy Variants:	
Key Words:		Publisher Preferred Rates:	
Test Procedure Version:	2.3	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Substitution (B3), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	kathy.ellis	Subscriber Preferred Variants:	
Approval Date:	09/05/2015	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:28 PM - Herbert Falk

- File 12-01513_Mikronika_SO-52v11_Certificate.pdf added

Files

12-01513_Mikronika_SO-52v11_Certificate.pdf	289 KB	07/08/2021	Herbert Falk
---	--------	------------	--------------