

# IEC 61850 Certificate - IEC 61850 Certificate #2183

## SO-55 [Mikronika]

07/08/2021 04:28 PM - Herbert Falk

<b>Status:</b>	Approved	<b>Test Document:</b>	
<b>Priority:</b>	Normal	<b>Certificate Name:</b>	74101901-MOC/INC 12-01515
<b>61850 Edition:</b>	Edition 1	<b>Certificate Hash:</b>	C7FF32C82DFBA8E02DC6F8877C68F 70C58177C290597C24AF5AF0722B7A F0554
<b>61850 Tested Aspects:</b>	Server	<b>Vendor Artifact File Name:</b>	
<b>Company:</b>	Mikronika	<b>Vendor Artifact Hash:</b>	
<b>Address:</b>	60-001 Poznan Wykopy 2/4 Poland	<b>Umbrella Organization:</b>	
<b>Product:</b>	SO-55	<b>Optional Reservation Test:</b>	No
<b>HW Version:</b>		<b>Serial Number:</b>	
<b>SW Version:</b>	1.4	<b>Publisher Legacy Variants:</b>	
<b>Key Words:</b>		<b>Publisher Preferred Rates:</b>	
<b>Test Procedure Version:</b>	2.3	<b>Publisher Preferred Variants:</b>	
<b>IEC 61850 Blocks Certified:</b>	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Substitution (B3), Time Synchronization (B13), Unbuffered Reporting (B5)	<b>Subscriber Legacy Variants:</b>	
<b>Certificate/Result Reviewer:</b>	kathy.ellis	<b>Subscriber Preferred Variants:</b>	
<b>Approval Date:</b>	09/05/2015	<b>Subscriber Preferred Rates:</b>	
<b>Standards Tested:</b>	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
<b>Current Test Lab Name:</b>	DNV Netherlands (A)		

### Description

This certificate and its information was migrated from a previous database

### History

#1 - 07/08/2021 04:28 PM - Herbert Falk

- File 12-01515\_Mikronika\_SO55\_Certificate.pdf added

### Files

12-01515_Mikronika_SO55_Certificate.pdf	291 KB	07/08/2021	Herbert Falk
---	--------	------------	--------------