

IEC 61850 Certificate - IEC 61850 Certificate #2185

RFI 401 D3 [RoCon PLC]

07/08/2021 04:28 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	74101682-MOC/INC 12-01682
61850 Edition:	Edition 1	Certificate Hash:	AAD55E44A3AEC881E27B7B68C7C42 8CC39298CFE1E0B3FAB0BF87E02FB A6EC25
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	RoCon PLC	Vendor Artifact Hash:	
Address:	56A, 21 Vek Str. 1700 Sofia Bulgaria	Umbrella Organization:	
Product:	RFI 401 D3	Optional Reservation Test:	No
HW Version:		Serial Number:	
SW Version:	1.030	Publisher Legacy Variants:	
Key Words:		Publisher Preferred Rates:	
Test Procedure Version:	2.3	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Setting Group (B4), Setting Group Definition (B4+), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	kathy.ellis	Subscriber Preferred Variants:	
Approval Date:	09/05/2015	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:28 PM - Herbert Falk

- File 12-01682_RoCon_RFI_401_D3_Certificate.pdf added

Files

12-01682_RoCon_RFI_401_D3_Certificate.pdf	316 KB	07/08/2021	Herbert Falk
---	--------	------------	--------------