

# IEC 61850 Certificate - IEC 61850 Certificate #2191

## Reyrolle 7SR224 [Siemens Protection Devices Limited]

07/08/2021 04:28 PM - Herbert Falk

<b>Status:</b>	Approved	<b>Test Document:</b>	
<b>Priority:</b>	Normal	<b>Certificate Name:</b>	74102036-MOC/INC 12-01953
<b>61850 Edition:</b>	Edition 1	<b>Certificate Hash:</b>	A2F0125E50444831C69810E104DCFE 2A2233583851217E5328DCD0DA12E4 60EE
<b>61850 Tested Aspects:</b>	Server	<b>Vendor Artifact File Name:</b>	
<b>Company:</b>	Siemens Protection Devices Limited	<b>Vendor Artifact Hash:</b>	
<b>Address:</b>	North Farm Road, Hebburn Tyne & Wear, NE31 1LX United Kingdom	<b>Umbrella Organization:</b>	
<b>Product:</b>	Reyrolle 7SR224	<b>Optional Reservation Test:</b>	No
<b>HW Version:</b>	EN100 V04.08	<b>Serial Number:</b>	
<b>SW Version:</b>	7b	<b>Publisher Legacy Variants:</b>	
<b>Key Words:</b>	Protection, Relay	<b>Publisher Preferred Rates:</b>	
<b>Test Procedure Version:</b>	2.3	<b>Publisher Preferred Variants:</b>	
<b>IEC 61850 Blocks Certified:</b>	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced Buffered Reporting (B6+), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	<b>Subscriber Legacy Variants:</b>	
<b>Certificate/Result Reviewer:</b>	kathy.ellis	<b>Subscriber Preferred Variants:</b>	
<b>Approval Date:</b>	09/05/2015	<b>Subscriber Preferred Rates:</b>	
<b>Standards Tested:</b>	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
<b>Current Test Lab Name:</b>	DNV Netherlands (A)		
<b>Description</b>			
This certificate and its information was migrated from a previous database			

### History

#1 - 07/08/2021 04:28 PM - Herbert Falk

- File 12-01953\_SIEMENS\_7SR224\_Certificate.pdf added

### Files

12-01953_SIEMENS_7SR224_Certificate.pdf	234 KB	07/08/2021	Herbert Falk
---	--------	------------	--------------