

IEC 61850 Certificate - IEC 61850 Certificate #2195

TEC Server [ABB AB PPTR/AT]

07/08/2021 04:28 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	74101436-MOC/INC 12-02060
61850 Edition:	Edition 1	Certificate Hash:	6B8F817D61A5981E3BA95C75B6B103 CB139BD51318E7DF531232416A2D46 76F4
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	ABB AB PPTR/AT	Vendor Artifact Hash:	
Address:	Valhallavagen 2 771 80 Ludvika Sweden	Umbrella Organization:	
Product:	TEC Server	Optional Reservation Test:	No
HW Version:		Serial Number:	
SW Version:	2.3.0	Publisher Legacy Variants:	
Key Words:	Protection	Publisher Preferred Rates:	
Test Procedure Version:	2.3	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Data Sets (B2), Enhanced SBO Control (12d), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	kathy.ellis	Subscriber Preferred Variants:	
Approval Date:	09/05/2015	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		
Description			
This certificate and its information was migrated from a previous database			

History

#1 - 07/08/2021 04:28 PM - Herbert Falk

- File 12-02060_ABB_TECserver_Certificate.pdf added

Files

12-02060_ABB_TECserver_Certificate.pdf	254 KB	07/08/2021	Herbert Falk
--	--------	------------	--------------