IEC 61850 Certificate - IEC 61850 Certificate #2197

SERnet [Ametek Power Instruments]

07/08/2021 04:28 PM - Herbert Falk

Status:	Approved		
Priority:	Normal		
61850 Edition:	Edition 1	**Certificate Name:**	74102155-MOC/INC 12-02237
61850 Tested Aspects:	Server	**Certificate Hash:**	7C35BFC0C79F2D27C06B73CFA7300270F516A035237DB93DC6182C3B08845BC2
Company:	Ametek Power Instruments	**Vendor Artifact File Name:**	
Address:	255 North Union Street Rochester, NY 14605 USA	**Vendor Artifact Hash:**	
Product:	SERnet	**Umbrella Organization:**	
HW Version:		**Optional Reservation Test:**	No
SW Version:	1.0.0	**Serial Number:**	
Key Words:		**Publisher Legacy Variants:**	
Test Procedure Version:	2.3	**Publisher Preferred Rates:**	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Unbuffered Reporting (B5)	**Publisher Preferred Variants:**	
Certificate/Result Reviewer:	kathy.ellis	**Subscriber Legacy Variants:**	
Approval Date:	09/05/2015	**Subscriber Preferred Variants:**	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1	**Subscriber Preferred Rates:**	
Current Test Lab Name:	DNV Netherlands (A)	**Product Variants:**	
Test Document:			

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:28 PM - Herbert Falk

- File 12-02237_AMETEK_SERnet_Certificate.pdf added

Files

12-02237_AMETEK_SERnet_Certificate.pdf	276 KB	07/08/2021	Herbert Falk