

IEC 61850 Certificate - IEC 61850 Certificate #2197

SERnet [Ametek Power Instruments]

07/08/2021 04:28 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	74102155-MOC/INC 12-02237
61850 Edition:	Edition 1	Certificate Hash:	7C35BFC0C79F2D27C06B73CFA73002 70F516A035237DB93DC6182C3B0884 5BC2
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	Ametek Power Instruments	Vendor Artifact Hash:	
Address:	255 North Union Street Rochester, NY 14605 USA	Umbrella Organization:	
Product:	SERnet	Optional Reservation Test:	No
HW Version:		Serial Number:	
SW Version:	1.0.0	Publisher Legacy Variants:	
Key Words:		Publisher Preferred Rates:	
Test Procedure Version:	2.3	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	kathy.ellis	Subscriber Preferred Variants:	
Approval Date:	09/05/2015	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		
Description			
This certificate and its information was migrated from a previous database			

History

#1 - 07/08/2021 04:28 PM - Herbert Falk

- File 12-02237_AMETEK_SERnet_Certificate.pdf added

Files

12-02237_AMETEK_SERnet_Certificate.pdf	276 KB	07/08/2021	Herbert Falk
--	--------	------------	--------------