

# IEC 61850 Certificate - IEC 61850 Certificate #2206

## UR N60 [GE Digital Energy]

07/08/2021 04:29 PM - Herbert Falk

<b>Status:</b>	Approved	<b>Test Document:</b>	
<b>Priority:</b>	Normal	<b>Certificate Name:</b>	74102335-MOC/INC 13-0451
<b>61850 Edition:</b>	Edition 1	<b>Certificate Hash:</b>	42FF2C7EDCF9B910E60704EFF3F658 38E7F67E0BE2D341D07BCC17F34E08 4F2D
<b>61850 Tested Aspects:</b>	Server	<b>Vendor Artifact File Name:</b>	
<b>Company:</b>	GE Digital Energy	<b>Vendor Artifact Hash:</b>	
<b>Address:</b>	650 Markland St. Markham, ON L6C 0M1 Canada	<b>Umbrella Organization:</b>	
<b>Product:</b>	UR N60	<b>Optional Reservation Test:</b>	No
<b>HW Version:</b>		<b>Serial Number:</b>	
<b>SW Version:</b>	7.10	<b>Publisher Legacy Variants:</b>	
<b>Key Words:</b>		<b>Publisher Preferred Rates:</b>	
<b>Test Procedure Version:</b>	2.3	<b>Publisher Preferred Variants:</b>	
<b>IEC 61850 Blocks Certified:</b>	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	<b>Subscriber Legacy Variants:</b>	
<b>Certificate/Result Reviewer:</b>	kathy.ellis	<b>Subscriber Preferred Variants:</b>	
<b>Approval Date:</b>	09/07/2015	<b>Subscriber Preferred Rates:</b>	
<b>Standards Tested:</b>	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
<b>Current Test Lab Name:</b>	DNV Netherlands (A)		

### Description

This certificate and its information was migrated from a previous database

### History

#1 - 07/08/2021 04:29 PM - Herbert Falk

- File 13-0451\_GE\_UR\_N60\_B30\_B90\_C30\_C60\_C70\_D30\_D60\_F35\_F60\_G30\_G6 added

### Files

13-0451\_GE\_UR\_N60\_B30\_B90\_C30\_C60\_C70\_D30\_D60\_F35\_F60\_G30\_G6.pdf 07/08/2021

Herbert Falk