

IEC 61850 Certificate - IEC 61850 Certificate #2207

SEL-2411 [Schweitzer Engineering Laboratories, Inc.]

07/08/2021 04:29 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	74102139-MOC/INC 13-0613
61850 Edition:	Edition 1	Certificate Hash:	AFC5B4DE44B7AB700C9F8C72B0D84 E2A14000CFD9780BF7AD664DD7DE3 6A03E3
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	Schweitzer Engineering Laboratories, Inc.	Vendor Artifact Hash:	
Address:	2350 NE Hopkins Court Pullman, WA 99163-5603 USA	Umbrella Organization:	
Product:	SEL-2411	Optional Reservation Test:	No
HW Version:		Serial Number:	
SW Version:	R310	Publisher Legacy Variants:	
Key Words:		Publisher Preferred Rates:	
Test Procedure Version:	2.3	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	kathy.ellis	Subscriber Preferred Variants:	
Approval Date:	09/07/2015	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:29 PM - Herbert Falk

- File 13-0613_SEL-2411_Certificate.pdf added

Files

13-0613_SEL-2411_Certificate.pdf

292 KB

07/08/2021

Herbert Falk