

IEC 61850 Certificate - IEC 61850 Certificate #2211

MiCOMho P443 [ALSTOM Grid UK LTD]

07/08/2021 04:29 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	74100457-MOC/INC 13-0779
61850 Edition:	Edition 1	Certificate Hash:	B09E5C2D2B98B19C745AF492FBBF5 D14FCE40C2A0C58233FB099C15D41F EA2DA
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	ALSTOM Grid UK LTD	Vendor Artifact Hash:	
Address:	St. Leonards Avenue Stafford ST17 4LX United Kingdom	Umbrella Organization:	
Product:	MiCOMho P443	Optional Reservation Test:	No
HW Version:	M	Serial Number:	
SW Version:	71C	Publisher Legacy Variants:	
Key Words:	Distance, Protection, Relay	Publisher Preferred Rates:	
Test Procedure Version:	2.3	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	kathy.ellis	Subscriber Preferred Variants:	
Approval Date:	09/07/2015	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:29 PM - Herbert Falk

- File 13-0779_AlstomGrid_P443_Certificate.pdf added

Files

13-0779_AlstomGrid_P443_Certificate.pdf	195 KB	07/08/2021	Herbert Falk
-----------------------------------------	--------	------------	--------------