

IEC 61850 Certificate - IEC 61850 Certificate #2214

GRE110 [Toshiba Corporation]

07/08/2021 04:29 PM - Herbert Falk

| | | | |
|-------------------------------------|--|---------------------------------------|--|
| Status: | Approved | Test Document: | |
| Priority: | Normal | Certificate Name: | 74102109-MOC/INC 13-0939 |
| 61850 Edition: | Edition 1 | Certificate Hash: | 9B85D047696845A14CBA520261B17F2 CDC48EBF95D0A1FFA850B77AE2D8F 3A21 |
| 61850 Tested Aspects: | Server | Vendor Artifact File Name: | |
| Company: | Toshiba Corporation | Vendor Artifact Hash: | |
| Address: | Power Systems Protection and Control Fuchu-Complex 1, Toshiba-Cho Fuchu-shi, Tokyo, 183-8511 Japan | Umbrella Organization: | |
| Product: | GRE110 | Optional Reservation Test: | No |
| HW Version: | | Serial Number: | |
| SW Version: | GS1EM1-01-E | Publisher Legacy Variants: | |
| Key Words: | Protection | Publisher Preferred Rates: | |
| Test Procedure Version: | 2.3 | Publisher Preferred Variants: | |
| IEC 61850 Blocks Certified: | Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Setting Group (B4), Unbuffered Reporting (B5) | Subscriber Legacy Variants: | |
| Certificate/Result Reviewer: | kathy.ellis | Subscriber Preferred Variants: | |
| Approval Date: | 09/07/2015 | Subscriber Preferred Rates: | |
| Standards Tested: | 61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1 | | |
| Current Test Lab Name: | DNV Netherlands (A) | | |

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:29 PM - Herbert Falk

- File 13-0939_Toshiba_GRE110_Certificate.pdf added

Files

| | | | |
|--|--------|------------|--------------|
| 13-0939_Toshiba_GRE110_Certificate.pdf | 302 KB | 07/08/2021 | Herbert Falk |
|--|--------|------------|--------------|