

# IEC 61850 Certificate - IEC 61850 Certificate #2216

## SCD5200 [Invensys Operations Management]

07/08/2021 04:29 PM - Herbert Falk

<b>Status:</b>	Approved	<b>Test Document:</b>	
<b>Priority:</b>	Normal	<b>Certificate Name:</b>	74104097-MOC/INC 13-1178
<b>61850 Edition:</b>	Edition 1	<b>Certificate Hash:</b>	9A84E829416A2F596DF1D2B56A2016 DF02E40B3181C9146D58E4C4E7588F CAA4
<b>61850 Tested Aspects:</b>	Server	<b>Vendor Artifact File Name:</b>	
<b>Company:</b>	Invensys Operations Management	<b>Vendor Artifact Hash:</b>	
<b>Address:</b>	5601 Granite Parkway III, Suite 1000 Plano, Texas 75024 USA	<b>Umbrella Organization:</b>	
<b>Product:</b>	SCD5200	<b>Optional Reservation Test:</b>	No
<b>HW Version:</b>		<b>Serial Number:</b>	
<b>SW Version:</b>	SY-1101205_F	<b>Publisher Legacy Variants:</b>	
<b>Key Words:</b>		<b>Publisher Preferred Rates:</b>	
<b>Test Procedure Version:</b>	2.3	<b>Publisher Preferred Variants:</b>	
<b>IEC 61850 Blocks Certified:</b>	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Substitution (B3), Unbuffered Reporting (B5)	<b>Subscriber Legacy Variants:</b>	
<b>Certificate/Result Reviewer:</b>	kathy.ellis	<b>Subscriber Preferred Variants:</b>	
<b>Approval Date:</b>	09/07/2015	<b>Subscriber Preferred Rates:</b>	
<b>Standards Tested:</b>	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
<b>Current Test Lab Name:</b>	DNV Netherlands (A)		

### Description

This certificate and its information was migrated from a previous database

### History

#1 - 07/08/2021 04:29 PM - Herbert Falk

- File 13-1178\_Invensys\_SCD5200\_Server\_Certificate.pdf added

### Files

13-1178_Invensys_SCD5200_Server_Certificate.pdf	314 KB	07/08/2021	Herbert Falk
---	--------	------------	--------------