

# IEC 61850 Certificate - IEC 61850 Certificate #2217

## SEL-421 [Schweitzer Engineering Laboratories, Inc.]

07/08/2021 04:29 PM - Herbert Falk

<b>Status:</b>	Approved	<b>Test Document:</b>	
<b>Priority:</b>	Normal	<b>Certificate Name:</b>	74102139-MOC/INC 13-1218
<b>61850 Edition:</b>	Edition 1	<b>Certificate Hash:</b>	E3E8ABB04CFE28450F4025528CE380 76687091F420BA62B44AE6D950F78E5 DFD
<b>61850 Tested Aspects:</b>	Server	<b>Vendor Artifact File Name:</b>	
<b>Company:</b>	Schweitzer Engineering Laboratories, Inc.	<b>Vendor Artifact Hash:</b>	
<b>Address:</b>	2350 NE Hopkins Court Pullman, WA 99163-5603 USA	<b>Umbrella Organization:</b>	
<b>Product:</b>	SEL-421	<b>Optional Reservation Test:</b>	No
<b>HW Version:</b>		<b>Serial Number:</b>	
<b>SW Version:</b>	R313	<b>Publisher Legacy Variants:</b>	
<b>Key Words:</b>	Protection	<b>Publisher Preferred Rates:</b>	
<b>Test Procedure Version:</b>	2.3	<b>Publisher Preferred Variants:</b>	
<b>IEC 61850 Blocks Certified:</b>	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Time Synchronization (B13), Unbuffered Reporting (B5)	<b>Subscriber Legacy Variants:</b>	
<b>Certificate/Result Reviewer:</b>	kathy.ellis	<b>Subscriber Preferred Variants:</b>	
<b>Approval Date:</b>	09/07/2015		
<b>Standards Tested:</b>	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
<b>Current Test Lab Name:</b>	DNV Netherlands (A)		

### Description

This certificate and its information was migrated from a previous database

### History

#1 - 07/08/2021 04:29 PM - Herbert Falk

- File 13-1218\_SEL-421\_Certificate.pdf added

### Files

13-1218_SEL-421_Certificate.pdf	296 KB	07/08/2021	Herbert Falk
---------------------------------	--------	------------	--------------